



GSXZ.R21720 Special-purpose Fire Doors

[Page Bottom](#)

Special-purpose Fire Doors

[See General Information for Special-purpose Fire Doors](#)

ALUFLAM NORTH AMERICA L L C

R21720

16604 Edwards Rd
Cerritos, CA 90703 USA

Special purpose type fire door and frame assembly, with transom and or side lights, maximum rating 1 hr. May be installed into either gypsum wallboard or masonry walls. Overall frame size not to exceed 120 in. in height or in width.

Special purpose type fire door and frame assembly, with transom and or side lights, maximum rating 1-1/2 hr. May be installed into either gypsum wallboard or masonry walls. Overall frame size not to exceed 98-3/8 in. in height or 88-7/8 in. in width.

Also Classified in accordance with UL10C.

[Last Updated](#) on 2012-12-03

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2014 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2014 UL LLC".